

EdCIL\BM\Fire Fighting\C-AMC\2023

Dated 13/01/2023

Sub.: Quotation for Non Comprehensive Annual Maintenance Contract for Fire Fighting System at EdCIL India Limited, 18A, Sector 16A, Noida -201301

Sir,

EdCIL (India) Limited intends to award a Non Comprehensive Annual Maintenance Contract of Automatic Fire Alarm System with PA system and Fire Fighting and Sprinkler System installed at EdCIL India Ltd, Noida for a period of 12 months to reputed firms having adequate experience in the maintenance of Fire Fighting Systems and are associated with Government Department/Public Sectors etc.

The quotation duly filled for "NON COMPREHENSIVE ANNUAL MAINTENANCE CONTRACT FOR FIRE FIGHTING SYSTEM" as per the Annexure-I, II must be sent in a sealed cover to Manager (HR & Admin.), EdCIL (India) Limited, EdCIL House, 18A, Sector-16A, NOIDA- 201301 latest by 23/01/2023 at 15.00 Hrs.

# GENERAL CONDITIONS /INSTRUCTIONS FOR SUBMISSION OF BIDS/APPLICATIONS/ TENDERS

- 1 Sealed tenders are invited under Single Bid system directly from the established, registered, reputed Fire Fighting agencies/firms and having sufficient Infrastructures for providing of Fire fighting services.
- 2 The Bid should be in sealed envelopes to be put into another envelope and it should be super scribed as "Tender for AMC of Fire Fighting System for NOIDA office".
- 3 The last date of receipt of offer in a sealed envelope as mentioned above and addressed to Manager (HR & Admin.), EdCIL (India) Limited, EdCIL House, 18A, Sector-16A, NOIDA- 201301 is on or before 23/01/2023 at 1500 hrs. in a sealed tender box kept in the ground floor of Corporate Office, NOIDA.
- 4 The Earnest Money Deposit (EMD) of Rs. 5,100/- (Rupees Five thousand One Hundred Only) in the form of Demand Draft/pay order drawn in favour of "EdCIL (India) Limited" payable at Noida is to be submitted along with the bid. Agencies registered with MSME/NSIC are exempted from EMD Submission.
- 5 AMC Rates on various items will be finalized after scrutinizing /checking the commercial bids and the successful bidder will be communicated through the Letter of Intent (LOI).

- 6 The EMDs of the unsuccessful bidders will be refunded without any interest.
- 7 All the pages/documents of the Tender should bear the dated signature of the tenderer. All the entries by the tenderer should be in one ink & legibly written. Any over-writing corrections & cuttings should bear dated initials of the tenderer. Corrections should be made by writing again instead of shaping or over-writing.
- 8 Rates should be quoted both in figures as well as in words. In case the rates quoted in words & figures are at variance, the rates written in words will be taken as final.
- 9 EdCIL reserves the right to reject or accept any or all application(s) without assigning any reasons and to restrict the list of pre-qualified agencies to any number deemed suitable by it, if too many tenderers /bidders are received satisfying the basic pre-requisite criteria.
- 10 Conditional tenders are liable to be rejected.
- 11 It is advised that Tenderer must visit the sites for assessment of job and site conditions on any working day during working hours. The contact details are as under:-

#### Corporate Office:-

Mr. Rahul Sharma 0120-4516001-002 (Extn. 220)

Mr. Avinash Kr. Singh AM (HR& Admin) 0120-4516001-002, 4514003, (Extn. 211)

## <u>Summary/ Salient features of the tender for appointment of Fire Fighting Agencies</u>

S. No.	Particulars	Remarks	
1.	Type of tender	Single Bid System	
2.	Last date of submission of tender	1500 hrs. of 23/01/2023	
3.	Venue for submission of offer	Sealed tender box kept at ground floor of Corporate Office, NOIDA	
4.	EMD (refundable)	Rs.5100 /- in the form of pay order/	
5.	Date of opening of Bid	23/01/2023 at 1530 hrs.	
6.	Validity of offers	90 days from the date of opening of technical bids.	
7.	AMC Contract period	1 year after the award of AMC Order	
8.	Details/ address of the locations for which Fire Fighting services required	EdCIL (India) Ltd. EdCIL House, 18A, Sector-16A, NOIDA-201301	
9.	Brief description of the sites where Fire Fighting services are required	Corporate Office, NOIDA: The building is having Basement + Ground + four floors. Total super area is approx. 36500 Sq.Ft.	
10.	Details of the contact person for inspection of site	Corporate Office – Mr. Avinash Kr. Singh AM (HR& Admin) 0120-4516001-002 (Extn. 211)  Mr. Rahul Sharma 0120-4516001-002 (Extn. 220)	

The terms and conditions of the tender & resultant contract shall be as under:

#### (1) Eligibility Criteria in Technical Bid:

The quotationer should fulfill the following criteria and submit the following documents:

- 1.1) The agency should have satisfactory completed at least two similar type of works or more with CPWD/MES/Railways/PSUs/Central/State Government in last three years.
- 1.2) List of technical personnel and organizational set up of the agency to be Submitted.
- 1.3) List of similar works completed in last three years with documenting proof.
- 1.4) The agency should have GST, PAN registration and copies of the same to be submitted.
- 1.5) Supporting documents to establish that the firm has adequate experience in Repairing and maintenance of Fire Fighting System.

#### (2) Scope of Work for Repairing and AMC:

- 2.1) The term Maintenance shall include the service and labour charges for the following items as described in schedule of quantities, but is not limited to the same:
- 2.1.1) Hydrant system consisting of Internal Hydrant risers, External hydrant ring, Hydrant pumping station with all accessories such as Hydrants, Hoses, First Aid Hose Reel, and Branch Pipe etc.
- 2.1.2) Pumping system consisting of Hydrant pump, motor operated Standby pump, Diesel Pump, Jockey pump, terrace pumps and equipments such as Valves, strainers, Piping, Instrumentation and Motor Starting system.
- 2.1.3) Sprinkler system for the basement.
- 2.1.4) Fire alarm system and PA system for the entire buildings.
  - 2.2) Preventive maintenance of the entire Fire Fighting system shall be done every Month for which suitable technical person shall be deputed. For which the agency should maintain a log book and related documents.
  - 2.3) For breakdown maintenance of the machines the agency will depute at least one qualified mechanic/technician and fitter along with helper as and when required to visit EdCIL office.

2.4) The agency should conduct a mock drill of all FA/PA system once in a month along with the training of security guards/ employees in presence of an engineer of EdCIL.

#### (3) General Conditions:

- 3.1) Quotations from only those agencies will be entertained which are submitted within stipulated time for services desired in the tender.
- 3.2) The agency shall bear all costs associated with the preparations and submission of their bid and EdCIL will in no case be responsible or liable to these costs, regardless of the conduct or outcome of the bidding process.
- 3.3) The agency shall be responsible for handing over the entire system of Fire Fighting in working condition on expiry of the contract.
- 3.4) The damage caused, if any, either to machines or to any other property of EdCIL due to negligence or otherwise, shall be at the risk, cost and responsibility of the agency.
- 3.5) No extra payment/compensation whatsoever on account of natural calamity/accident or otherwise will be made to the agency by the EdCIL except for the rates permitted under this contract.
- 3.6) No advance payment will be made. The payment of AMC shall be made on quarterly basis i.e. 25 percent of the total AMC amount in each quarter subject to the proper functioning of the Fire Fighting systems maintained by the agency, on submission of bills.
- 3.7) Complaints regarding the non-functioning of Fire Fighting System are to be attended within 24 hours of reporting the complaint. Any spare parts required for rectification work should be informed within 24 hours of attending the complaint. LD Clause will be levied upon the contractor @0.5% per day upto a maximum of 10%.
- 3.8) EdCIL reserves the right to reject or accept the quotations in whole or in part without assigning any reason.
- 3.9) The agencies registered with Medium, Small and Micro Enterprises (MSME/NSIC) will be given preference in finalizing agency as per the public procurement policy, 2012.
- 3.10) In case of agencies whose quotation are not considered for placing order, the Earnest Money deposit will be refunded without any interest within one month from the date of issue of purchase order to the successful agency.

3.11) Within 10 days of receipt of the Purchase order, the Bidder shall furnish one performance security of 03% of contract value valid for 15 months from the schedule date of starting of the assignment, failing which EMD of the same will be forfeited & the contract will be cancelled.

The above performance security should be in the form of Bank Guarantee in favour of EdCIL (India) Ltd issued by only a Nationalized Bank located in India.

3.12) If services are found unsatisfactory EdCIL reserves the right to terminate the AMC at any time. In all matters of dispute relating to the proposed AMC the decision of EdCIL (India) Ltd. shall be final and binding of the agency.

#### 3.13) Arbitration and Settlement of Disputes:

EdCIL and the supplier shall make every effort to resolve amicably by direct informal negotiation any difference or dispute arising between them under or in connection with EdCIL order.

If after thirty (30) days from the commencement of such informal negotiations, EdCIL and the supplier have been unable to resolve amicably the dispute; either party may require that the dispute be referred for resolution to the formal mechanisms as specified here under:

- a) Any dispute or differences whatsoever arising between the parties out of or relating to the construction, meaning, scope, operation or effect of this contract or the validity or the breach thereof shall be settled by arbitration in accordance with the provisions of the Arbitrations & Conciliation Act,1996 and the award made in pursuance thereof shall be binding on the parties. The arbitrator shall be the Chairperson and Managing Director, EdCIL or any other person appointed/ nominated by him.
- b) The performance under this contract shall not stop for any reason whatsoever during the said dispute/proceedings, unless the service provider is specifically directed by EdCIL to desist from working in this behalf.
- c) The venue of arbitration shall be in Delhi.
- d) The language of proceedings shall be in English.
- e) The Law governing the substantive issues between the parties shall be the Laws of India.

It is also a term of the contract that if any fees are payable to the arbitrator, these shall be paid equally by both the parties.

#### EdCIL\BM\Fire Fighting\C-AMC\2023

It is also a term of the contract that the arbitration shall be deemed to have commenced on the date of the arbitrator issues notice to both the parties calling them to submit their statement of claims and counter statement of claims.

Yours faithfully,

Sd/xxx Sushant Dey Manager (HR & Admin)

### Annual Maintenance Contract for Fire Fighting System at EdCIL INDIA LTD., 18-A, Sector 16-A, Noida-201301.

1.	Name of the tenderer (in Block Letter)					
2.	Address					
3.	Telep	hone No.				
4.	Detail of enclosed Bank Draft towards EMD					
	Ban Nam	k & Branch ne	DD No. & Date	Amount (	Rs.)	
5.		stration No. of the se enclosed the	e Firm copy of registration	on)		
6.	GST No					
7.	PAN No					
8.	<u>Expe</u>	<u>rience</u>				
	SI. No.	Experience in r Fire Fighting Sy Deptt./Organiza (please enclose the work order)	ystem in Govt. ation ed the copies of	Name of the Deptt./Org.	Period of Services	Value of work order ( in Rs.)
condit	ions o	f the contract as	ffirm that I/We h stipulated in the Fighting System			
				Si	gnature	
					ame	
						(in block letter)
					Official	Seal of the firm

### AMC Charges for FIRE FIGHTING SYSTEM

SI. No.	Description	Amount (Exclusive of GST) (Rs.)	GST (in Rs.)	Total Amount (Inclusive of GST) (Rs.)
, 1.	Full Comprehensive Annual Maintenance Service contract including replacement of minor spare parts. The building comprises of basement, ground floor and four floors above with details as under:			
	Total plot area: 3000 sq.mtrs.			
	Basement Area: 359.17 sq.mtrs.			
	Ground floor : 747.76 sq.mtrs.			
	First floor : 535.13 sq.mtrs.			
	Second floor : 588.44 sq.mtrs.			
	Third floor : 473.49 sq.mtrs.			
	Fourth floor : 493.49 sq.mtrs.			
	Sprinkler System is in basement area only.			
	Fire Alarm System			
	Main Panel six Zone – 1 nos			
	Repeater Panel - 4 nos consisting of 4,6,8,12 zone panels			
	Checking and Testing of devices i.e. Hooters, Detectors MCP, R.I – 100 nos			
	Main Pump -25 hp			
	Jockey pump- 7.5 hp			
	Terrace pump- 12 hp			

### EdCIL\BM\Fire Fighting\C-AMC\2023

Diesel Pump – 51 BHP	
Fire Hydrant system – 8 nos	

Amount in Words (Exclusive of GST) (Rs.):-

Amount in Words (Inclusive of GST) (Rs.)

Signature	
Name	
	(in block letter)

Official Seal of the firm